



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/School/WZ/2025/646

Dated:- 13/05/2025

FIRE SAFETY CERTIFICATE

Certified that the **G.D. Goenka Public School**, Located at **Main Rohtak Raod**, **Opposite Metro Pillar No. 497, Mundka, New Delhi-110041**, running at **basement + ground + 01 upper floor only** in a building comprised of basement + ground + 02 upper floors, owned/occupied by **G.D. Goenka Public School** have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of Fire Service on 29/04/2025 in the presence of Sh. Naveen Kumar Lakra (Chairman) and that the building/premises is fit for occupancy class **"Educational Building" Group-B (Basement + Ground + 01 Upper Floor only)** with effect from 13/05/2025 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on 13/05/2025 at New Delhi by

(Atul Garg)
Director

Tel. No. 011-23414000

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054
2. The Principal, G.D. Goenka Public School, Main Rohtak Road, Opposite Metro Pillar No. 497, Mundka, New Delhi-110041.

Conditions for the validity of fire safety certificate:-

1. This FSC is valid for basement, ground & one upper floor only.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
6. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
7. All comments / directions of licensing Department shall always be permitted and followed.
8. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
9. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.
10. The basement shall be used as per UBBL.
11. The school management has given an undertaking that the building was initially constructed with double basement with ground plus two stories but during construction, second basement was filled and sealed. And on second floor renovation work is going on & during occupancy of the school renovation work will not be carried out. If found the same FSC shall be treated as null & void.